

## **SUMMARY OF THE MOST SAFETY CONCERNS**

1. Repair the crack in the west side walkway to prevent trip hazard.
2. Fill underneath of the stair to prevent break in the concrete stairs which could cause a trip hazard.
3. Fix the brick walkway on the east side to prevent any hazard and getting worst.
- 4- Adjust the spring for garage door for safety precautions.
- 5- Install grounding wire for gas line to prevent any probable fire hazard in this regard.
- 6- Remove the home made panel and added 40 ampere cable by a licensed contractor in order to prevent any fire or shock hazards.
- 7- Install an operable Co alarm right next to the entrance door from garage; its absence could cause a safety issue.
- 8- Clean the air filter for the furnace regularly, or exchange it with a clean one.
- 9- Install weather stripping and self closing device for the garage door to the house which is a safety issue.
- 10- Change the dented gas-dryer's vent with undamaged circular solid metal vent.
- 11- Make the shelves, over the crawl space hatch door, removable to prevent any hazard.
- 12- Change the sharp edges of the window sills to round ones, in the north-west living room, in order to prevent any hazards for small children.

